



PRODUCT CERTIFICATE OF REGISTRATION

FujiClean Australia Pty Ltd

2/176 Siganto Drive, Helensvale, QLD 4212, Australia

Product Performance Testing

1546.3:2017

Advanced Secondary 3000 L/day or 20EP level with a reduction of 61.25% for Nitrogen and 6.49% for Phosphorus

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
FujiClean ACE 3000	Yes	TSS: 4.98mg/l BOD5: 1.29mg/l E Coli: 0.20 CFU/100mL Nitrogen: 29.37mg/L Phosphorous: 10.66mg/L	3 Month Service 2.3 yearly sedimentation pump out or as required	Pumped via disinfection/pump chamber with chlorine dispenser	Manufactured and Assembled: 59 Computer Road, Yatala, QLD 4207, Australia Or 37 Wells Road, Mordialloc, VIC 3195, Australia
The system took 1 week to meet the advanced secondary standard. No additives apart from Chlorine for disinfection was added to the system during testing. The tanks are certified to AS/NZS 1546.1:2008					

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (AWTS)" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.


Evan Miller - General Manager
Compass Assurance Services Pty Ltd



CERTIFICATION DATE:

14 February 2021

DATE OF ISSUE:

30 January 2026

EXPIRY DATE:

14 February 2031

CERTIFICATE #:

8221-3568-01