

EPA VICTORIA STS APPROVAL ACE1200

FujiClean Australia Helensvale, QLD info@fujiclean.com.au

ACE1200 8 EP 1,200L/d

560g BOD5/d Single tank, fibre-reinforced plastic, horizontal orientation. Contains a primary settlement chamber, anaerobic filtration chamber, aerobic filtration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 5 years or as required

WWP-20162 15 March 2029 5627-3568-01

Expiry: 15 March 2029



1300 733 619
www.fujiclean.com.au
PO Box 1230, Oxenford, QLD 4210